

**Questions & Answers (#12-13), 4/6/12
Furnishing of Steel Structures and Equipment for the Frog Level**

**#1 Page 5 of 37 under scope – the list of what to supply 115 A-Frame Dead-end
5 equipment bays does not match the drawings- please explain**

#1 – ignore 115 kV A-frame deadend

**#2 The bill of material on item 81D list a Doss (Dossert) cat # GCF
This is an incomplete catalog #- and the description does not give a pipe size-**

**#2 – 81D is braided shunt for Cleveland Price switch operating pipe – I do not know the size of the pipe
at this time either**

**#3 The specs on page 16 of 37 under item 3.15 calls for a 3 ft. x 6 ft. grd platform with
2 compression terminals—
The bill of material—Items 8 calls for a 3 ft x 4 ft grd platform and item 8A is not compression but
bolted-
So- which do we go by- specs or bill of material?**

#3 Bill of materials - bolted connection for platform

**#4 Also—do we supply just the manufactures listed on the bill of material—
DOSS= Dossert
SEVES= SEVES—**

**#4 You can price the vendor of choice that meets equivalent specification, except Deutsch and
Cleveland Price.**