

GREENVILLE UTILITIES COMMISSION

QUESTIONS AND ANSWERS FOR 22-55

RFB FOR TRANSFORMERS

9/13/2022 at 3:00PM

Question:

For STK# 204900 the description on Page [#1](#) lists the secondary voltage as 120/240. On page [#6](#) in the description for STK# 204900 it lists the secondary voltage as 277. Which secondary voltage would GUC like for that item?

Answer:

Item II/stock #204900 specifications (page 4) should read

25 KVA Conventional Distribution Transformers, single phase 60 Hz, two-bushing cover mounted, 12470/7200 volt grounded wye primary to 120/240 volt secondary, 95 KV BIL, 65°C rise, no taps. Units are to be equipped with a pressure relief device, single hangers and neutral grounding strap and finished in high quality light gray paint.