

**GREENVILLE UTILITIES COMMISSION**  
**QUESTIONS AND ANSWERS FOR 23-03**  
**RFB FOR CAST IRON WATER METER BOXES**  
**1/24/2023 at 4:00PM**

1. Do you need the regular TR hole in the meter box not the version with the recessed TR hole?

Recessed holes are required if available in the approved meter boxes.

2. What are the approved Models?

TriCast: MSMBX-1-RH

Sigma: MB382TS

Capitol: MBX-1\*MOD