

GREENVILLE UTILITIES COMMISSION

**QUESTIONS AND ANSWERS II FOR RFB 22-61
FOR MULTIPLE HIGH PRESSURE GAS FACILITIES – STATION CONSTRUCTION**

AUGUST 29, 2022

- 1) We just wanted to make sure that this RFB is just for the construction of the Old Tar facility and does not include the Tull Road facility?

Correct, this RFB is just for the Old Tar Road Site.

- 2) On page 76 it states they are supplying the SS tubing. Is GUC supplying the fittings also?

All materials listed on Pages 21 and 22 (Bill of Materials) of the “IFC - Gate Station Replacement” drawings and on Page 9 (AC Mitigation Material List) of the “IFC – AC Mitigation” will be provided to the contractor. All other materials are considered incidental to the work and will be provided by the contractor.

- 3) On page 76 it states they are supplying the rigid conduit. Is GUC supplying both the underground and above ground conduit?

All materials listed on Pages 21 and 22 (Bill of Materials) of the “IFC - Gate Station Replacement” drawings and on Page 9 (AC Mitigation Material List) of the “IFC – AC Mitigation” will be provided to the contractor. All other materials are considered incidental to the work and will be provided by the contractor.

- 4) Is GUC supplying the conduit fittings?

All materials listed on Pages 21 and 22 (Bill of Materials) of the “IFC - Gate Station Replacement” drawings and on Page 9 (AC Mitigation Material List) of the “IFC – AC Mitigation” will be provided to the contractor. All other materials are considered incidental to the work and will be provided by the contractor.

- 5) On the electrical plan/cable schedule (dwg. E-027-0001044), the first three conduits listed are a lighter shade than the last 5. Are the first 3 (R-01 to R-03) existing?

Construction of this Gate Station is joint project between Greenville Utilities Commission and Piedmont Natural Gas (Duke Energy). The portions of the plans that are shaded are the responsibility of Piedmont Natural Gas.

- 6) On the electrical plan/cable schedule (dwg. E-027-0001044), the Conduits R-04 to R-08 do not show any cable. Please advise.

The Contractor is only responsible for installing the conduit runs. Greenville Utilities Commission will install the necessary cables.

- 7) In the drawing package, a lot of the drawings are shaded differently. Is the lighter shade existing?

Construction of this Gate Station is joint project between Greenville Utilities Commission and Piedmont Natural Gas (Duke Energy). The portions of the plans that are shaded are the responsibility of Piedmont Natural Gas.