

QUESTION AND ANSWERS IV FOR:

RFP #16-56, for Pre Engineered Maintenance Building 01/12/17

1. Do we want to heat the storage area to just below 50 degrees?
The storage area should be heated to a minimum of 49 degrees F.
2. Do we really want 20' x 12' offices?
The offices should be bid as shown on the sketch, approximately 12' x 20'.