

**GREENVILLE UTILITIES COMMISSION
Greenville, North Carolina**

**REQUEST FOR QUALIFICATIONS
Construction Manager at Risk (CMAR) Services**

WATER TREATMENT PLANT UPGRADE PHASE I

Addendum No. 2

To All Potential Respondents:

Construction Manager at Risk firms submitting Statements of Qualifications for the Project shall take note of the following changes, additions, deletions, clarifications, etc., in the Request for Qualifications. Please acknowledge the receipt of Addendum No. 2 by completing Attachment E and submitting with your Statement of Qualifications.

GENERAL QUESTIONS:

1. Is there a specific form to use for Attachment J – Acknowledgement of Potential Conflict of Interest?

Response: No specific form is required.

2. Is there a specific form to use for the 5 projects under Firm Experience?

Response: No specific form is required.

3. Is there a process diagram/P&ID available for the existing 22MGD plant available for distribution?

Response: Existing drawings of the GUC WTP will be shared with the selected CMAR firm.

4. Please confirm any general/anticipated shutdown limitations (seasonal constraints, min. number of pump available at all times, etc.)

Response: Full WTP shutdowns will be limited to 6 hours and need to be scheduled in advance with the Owner to coordinate with WTP production. Detailed construction sequencing and maintenance of plant operations during construction will be developed during project design in collaboration with the Owner, Design Engineer, and CMAR.

5. Will the 2- or 3-dimensional models that were created for the PER be made available?

Response: CAD or Revit models of proposed facilities are not available at this time to distribute to potential CMAR firms.

6. There was a request during the pre-submittal meeting to obtain a copy of the presentation that summarizes the Phase 1 Upgrades improvements.

Response: The presentation was distributed to registered CMAR firms

7. There was a request during the pre-submittal meeting to obtain a copy of the Preliminary Engineering Report (PER).

Response: The PER is in draft form and currently being reviewed by GUC. The final PER report will be shared with the selected CMAR as it is not expected to be available during this selection process.

SECTION 5.0 – PROJECT UNDERSTANDING AND APPROACH:

8. The third to last bullet in this section references section 6.3.2. Please note that this is an erroneous reference. This bullet should read:

Project Tracking/Reporting: Identify tools and strategies used to track project performance, if different from information presented in bullet 2 above.

