

GREENVILLE UTILITIES COMMISSION
QUESTIONS AND ANSWERS FOR 24-53
RFB FOR HUDSON SUBSTATION SITE WORK
9/19/2024 at 10:00 AM

1. Which plan should be used for the limits of stone and grading? Sheet C1.0 and C3.0 show 2 different limits?

Sheet C1.0 shows limits of stone.

Sheet C3.0 grading of entire site. All areas within the limit of disturbance/silt fence will be graded to elevations shown on C3.

2. Where should the 4" underdrain pipe in the bioretention area be tied into?

4" Perforated PVC to be terminated and capped underground.