

**GREENVILLE UTILITIES COMMISSION**  
**QUESTIONS AND ANSWERS FOR 25-15**  
**RFB FOR TWO (2) FAULT INTERRUPTERS**  
**4/8/2025 @ 2:00 PM**

1. Under the general section 8.1 of attached bid form, anchor bolts S-81365-1 have been specified. I also notice you have specified mounting pedestal height suffix E12 for the Boviet and E14 for the Northside. Would you like for us to quote the S-81365-2 anchor bolts for the Northside since it is using the taller E14 pedestal?

Yes, please quote the -2 anchor bolts for Northside.

2. Additionally, section 8.8 specifies 4 hole terminal pads; however, the tubing/conductor size is not specified. Do you know that information yet?

The intent of this section is to state that the pads on the device be compatible with either copper or aluminum, and be 4-hole NEMA configuration. Also, the tension (if we choose to connect wire) that each terminal can tolerate must be stated. This is to give us discretion in the field regarding what terminals we use on our bus or conductor that will be attaching to the device.